



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 02-1908
Inspection Number: 00203609

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 441 N RUSSELLVILLE RD FRANKTOWN
Job Type: Building
Description: AU - Barn
Scope of Work: New

Inspection Details

Inspection Date: 10/09/2002
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Danny Young
Charge Reinspection Fee: No