



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05268
Inspection Number: 03188225

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5167 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 07/21/2015
Inspection Time: 12:00 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: IREA
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Move panel out to be flush with drywall
- 2) Plastic bushing required on nipple in panel
- 3) UFER GEC must be 4 AWG
- 4) Intersystem bonding conductor must be 6 AWG
- 5) Furnace not wired