



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 15-12973
Inspection Number: 03192317

Building Inspection Report

Permit Information

Job Address: 16452 OAKMOOR PL PARKER
Job Type: Roofing
Description: Wood/Masonite Product - Primary Residence

Inspection Details

Inspection Date: 08/05/2015
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Approved
Inspected By: Jon Dickey
Charge Reinspection Fee: No