



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 00-0161  
Inspection Number: 00002340

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 9975 KEENAN ST HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 02/07/2000  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Approved  
**Inspected By:** Greg Lillmars  
**Charge Reinspection Fee:** No