Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 15-19055
Inspection Number: 03224632

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5982 PANTHER HOLLOWS LITTLETON
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/16/2015
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

No more than 10 openings on a 15 amp circuit
Nail plate req'd above the BR door