



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 15-16635  
Inspection Number: 03241860

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 14119 FOREST LN LARKSPUR  
Job Type: Building  
Description: RS - Residential  
Scope of Work: Addition

### Inspection Details

Inspection Date: 03/15/2016  
Inspection Time: 12:00 AM  
Inspection Type: Exterior Wall Sheathing  
Inspection Code: 104  
Outcome: Approved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No