Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 16-01942
Inspection Number: 03242760

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9319 SAND HILL WAY HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/18/2016
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: David Lewis
Charge Reinspection Fee: No

Comments

approved kitchen only