Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 16-01942
Inspection Number: 03243322

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9319 SAND HILL WAY HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/22/2016
Inspection Time: 12:00 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Disapproved
Inspected By: Courtney Arford
Charge Reinspection Fee: No

Comments

none installed - yet
recall