



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 15-16635
Inspection Number: 03247415

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 14119 FOREST LN LARKSPUR
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 04/12/2016
Inspection Time: 12:00 AM
Inspection Type: Hydronic Piping
Inspection Code: 120
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No