



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 15-16635
Inspection Number: 03258324

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 14119 FOREST LN LARKSPUR
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 06/06/2016
Inspection Time: 7:10 AM
Inspection Type: Control Lighting
Inspection Code: 100
Outcome: Cancelled
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Not needed