



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 16-08003  
Inspection Number: 03270754

## Building Inspection Report

### Permit Information

**Job Address:** 9986 GWENDELYN PL HIGHLANDS RANCH  
**Job Type:** Roofing  
**Description:** Composition - Primary Residence

### Inspection Details

**Inspection Date:** 07/26/2016  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Roofing  
**Inspection Code:** 34  
**Outcome:** Approved  
**Inspected By:** John Poch  
**Charge Reinspection Fee:** No