



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-02491  
Inspection Number: 03272391

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 10010 S PERRY PARK RD LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 08/01/2016  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Electric Trench Partial  
**Inspection Code:** 15  
**Outcome:** Approved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

3", 2", & 1-1/4" PVC from elev shaft to north foundation wall  
NO access to permit card