



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-02491
Inspection Number: 03274134

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10010 S PERRY PARK RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 08/05/2016
Inspection Time: 12:00 AM
Inspection Type: Underground Plumbing Partial
Inspection Code: 11
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

Ok on Main house U.G.
Need inspection on U.G. BETWEEN Foundations