Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 16-11083
Inspection Number: 03276914

Building Inspection Report

Permit Information

Job Address: 9809 CASTLE RIDGE CIR HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 08/16/2016
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Approved
Inspected By: Jon Dickey
Charge Reinspection Fee: No