



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 03-2405
Inspection Number: 00290415

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 7673 JARED WAY LITTLETON
Job Type: Building
Description: AU - Structural Repair
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/12/2003
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Dave Ransom
Charge Reinspection Fee: No