



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 16-11889
Inspection Number: 03283193

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 6268 LAKEPOINT PL PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 09/07/2016
Inspection Time: 4:58 PM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Cancelled
Inspected By: Rich Garrett
Charge Reinspection Fee: No

Comments

n/a