



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 16-14421  
Inspection Number: 03284521

## Building Inspection Report

### Permit Information

**Job Address:** 13236 PEACOCK DR LITTLETON  
**Job Type:** Roofing  
**Description:** Composition - Primary Residence

### Inspection Details

**Inspection Date:** 09/13/2016  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Roofing  
**Inspection Code:** 34  
**Outcome:** Disapproved  
**Inspected By:** Robert Nunnelley  
**Charge Reinspection Fee:** No

### Comments

need gutters installed      roof ok