



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 03-2424
Inspection Number: 00290795

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 14624 CROOKED TRAIL RD WOODLAND PARK
Job Type: Building
Description: AU - Garage
Scope of Work: New

Inspection Details

Inspection Date: 09/16/2003
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

No Comment