



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 16-14421
Inspection Number: 03286251

Building Inspection Report

Permit Information

Job Address: 13236 PEACOCK DR LITTLETON
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 09/19/2016
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Approved
Inspected By: Robert Nunnelley
Charge Reinspection Fee: No