



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 16-10409

Inspection Number: 03286755

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5542 ABBEYWOOD CIR HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 09/20/2016

**Inspection Time:** 12:00 AM

**Inspection Type:** Rough Frame

**Inspection Code:** 29

**Outcome:** Disapproved

**Inspected By:** Chris Fuller

**Charge Reinspection Fee:** No

### Comments

1. Complete Rough-in plumbing.
2. Water heater access needs to be 30 inches in front of tank.
3. Remove all float blocks
4. Foam seal around all extr. Elec. boxes.
5. 100 sq. inch Return Air needed by Final Insp.