



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 16-10409

Inspection Number: 03289084

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5542 ABBEYWOOD CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/27/2016

Inspection Time: 12:00 AM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Disapproved

Inspected By: Chris Fuller

Charge Reinspection Fee: No

Comments

1. Complete fireblocking in soffit areas.
2. Complete all Rough-in Plumbing.
3. Shower drain will need a "P trap" and we will need to insp. it before covering up.