



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 00-1880
Inspection Number: 00029161

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 159 DOVER CT CASTLE PINES
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/20/2000
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Jim Tague
Charge Reinspection Fee: No