



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 00-1880  
Inspection Number: 00029166

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 159 DOVER CT CASTLE PINES  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 05/25/2000  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Underground Plumbing  
**Inspection Code:** 12  
**Outcome:** Approved  
**Inspected By:** Jerry Wlodarek  
**Charge Reinspection Fee:** No