



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 16-10409
Inspection Number: 03289837

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5542 ABBEYWOOD CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/28/2016
Inspection Time: 2:59 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Cancelled
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

ALREADY PASSED.