



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 03-3144  
Inspection Number: 00300604

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 1076 COCHETOPA DR LARKSPUR  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 11/26/2003  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Underground Plumbing  
**Inspection Code:** 12  
**Outcome:** Disapproved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No

### Comments

No Comment