



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 15-16635
Inspection Number: 03314951

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 14119 FOREST LN LARKSPUR
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 01/18/2017
Inspection Time: 1:59 PM
Inspection Type: Final Driveway
Inspection Code: 43
Outcome: Cancelled
Inspected By: Jill Welle
Charge Reinspection Fee: No

Comments

inspection not required