



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 16-15042  
Inspection Number: 03321686

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 6176 TORREY PINES DR LARKSPUR  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 02/21/2017  
Inspection Time: 12:00 AM  
Inspection Type: Moisture Barrier  
Inspection Code: 53  
Outcome: Disapproved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No

### Comments

- 1) Need to install weep screeds at bottom terminations
- 2) Need to install roll lock flashing top stone to stucco