



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-02933
Inspection Number: 03331146

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10663 AMESBURY WAY HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/05/2017
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Disapproved
Inspected By: Chris Fuller
Charge Reinspection Fee: No

Comments

3-rings, dog barking, no answer 9:30 a.m.