



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-02933  
Inspection Number: 03331948

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 10663 AMESBURY WAY HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 04/10/2017  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Disapproved  
**Inspected By:** Rick Sugar  
**Charge Reinspection Fee:** No

### Comments

Bathroom exhaust fan not installed