



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 14-02491
Inspection Number: 03332526

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10010 S PERRY PARK RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 04/14/2017
Inspection Time: 12:00 AM
Inspection Type: Exterior Wall Sheathing
Inspection Code: 104
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No