



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 16-15042  
Inspection Number: 03337813

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 6176 TORREY PINES DR LARKSPUR  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 05/08/2017  
Inspection Time: 12:00 AM  
Inspection Type: Final Electric  
Inspection Code: 42  
Outcome: Disapproved  
Inspected By: Rick Sugar  
Charge Reinspection Fee: No

### Comments

Scanned ticket