



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-04021
Inspection Number: 03344088

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10540 WESTCLIFF WAY HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/08/2017
Inspection Time: 3:27 PM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Cancelled
Inspected By: Robert Stratton
Charge Reinspection Fee: No

Comments

OWNER