



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-02933
Inspection Number: 03344183

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10663 AMESBURY WAY HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/09/2017
Inspection Time: 8:30 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Cancelled
Inspected By: Matt Mazzara
Charge Reinspection Fee: No

Comments

No one 18yrs old home