



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-05288
Inspection Number: 03352770

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3724 SERAMONTE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/25/2017
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Chris Fuller
Charge Reinspection Fee: No

Comments

kit remode