



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 17-08693
Inspection Number: 03357622

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 121 SILVER LEAF WAY CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/18/2017
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: David Lewis
Charge Reinspection Fee: No