



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-07014

Inspection Number: 03357807

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 11049 MEADOWVALE CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

### Inspection Details

Inspection Date: 08/22/2017

Inspection Time: 12:00 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

### Comments

- 1)Dry bar outlets req AFCI
- 2)Bsmt stair/hall lights req AFCI
- 3)No CO det upstairs