



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 14-02491  
Inspection Number: 03359084

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 10010 S PERRY PARK RD LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 08/25/2017  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Roof Truss  
**Inspection Code:** 127  
**Outcome:** Disapproved  
**Inspected By:** Clayton Rodeback  
**Charge Reinspection Fee:** No

### Comments

Strong back F01 gable.  
Missing Gsset F03 bottom cord.  
Missing Gusset F07 vert upright x2  
XX01 Girder missing 1/2' through bolts per spec or provide letter.  
Provide Uplift hardware west end of end of XXO1  
Provide layout sheet.