



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-05288
Inspection Number: 03361164

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3724 SERAMONTE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/06/2017
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Cooktop j-box: Bond with largest EGC / must use listed Cu to Al terminations
- 2) Same as #1 at wall ovens (leave acces to j-box for inspector OR provide photos if access not possible)
- 3) Install breaker locks for Oven & Cooktop