



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-09603

Inspection Number: 03364781

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 7827 TWO RIVERS CIR PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/25/2017

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

1. Recep req'd w/in 3' of j and j bath lav 2. Light req'd in sump closet 3. 2' wall at bedroom req's recep 4. 1/4" sheath req'd in box at stair 2gang box 5. 4-NM's max per plastic stackits