



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-09603

Inspection Number: 03365060

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 7827 TWO RIVERS CIR PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/26/2017

Inspection Time: 12:00 AM

Inspection Type: Insulation Thermal

Inspection Code: 36

Outcome: Approved

Inspected By: Rich Garrett

Charge Reinspection Fee: No