



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-07905
Inspection Number: 03367942

Building Inspection Report

Permit Information

Job Address: 4506 SILVER WING CT CASTLE ROCK
Job Type: Mechanical
Description: Air Conditioner (Primary Residence)

Inspection Details

Inspection Date: 10/12/2017
Inspection Time: 12:00 AM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

1) tamperproof caps required on refrig. ports; 2) sleeve t-stat cable from house into a/c unit