



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-00418  
Inspection Number: 03372544

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 9125 CORRAL LN CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 11/06/2017  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

- 1)All outlets req TR type
- 2)Smokes req 120 volt, battery back up and inter connected thru out
- 3)AFCI per 2011 NEC