



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-08966  
Inspection Number: 03374435

## Building Inspection Report

### Permit Information

**Job Address:** 5045 MCCLURE LN CASTLE ROCK  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 11/17/2017  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final HVAC  
**Inspection Code:** 39  
**Outcome:** Approved  
**Inspected By:** David Lewis  
**Charge Reinspection Fee:** No