



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-07906  
Inspection Number: 03375562

## Building Inspection Report

### Permit Information

**Job Address:** 4200 MOHAWK DR LARKSPUR

**Job Type:** Mechanical

**Description:** Air Conditioner (Primary Residence)

### Inspection Details

**Inspection Date:** 11/22/2017

**Inspection Time:** 12:00 AM

**Inspection Type:** Final HVAC

**Inspection Code:** 39

**Outcome:** Disapproved

**Inspected By:** Rich Edgett

**Charge Reinspection Fee:** No

### Comments

- 1) 10-3 NMB not permitted outdoors (Even in raceway)
- 2) Protect control wire outdoors from critters