



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-07906  
Inspection Number: 03376150

## Building Inspection Report

### Permit Information

**Job Address:** 4200 MOHAWK DR LARKSPUR  
**Job Type:** Mechanical  
**Description:** Air Conditioner (Primary Residence)

### Inspection Details

**Inspection Date:** 11/22/2017  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

See HVAC