



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 03-4116
Inspection Number: 00316988

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 6410 ROXBOROUGH PARK RD LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 11/19/2004
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Dave Ransom
Charge Reinspection Fee: No