



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 03-4116
Inspection Number: 00316992

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 6410 ROXBOROUGH PARK RD LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 08/19/2004
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: John Mulligan
Charge Reinspection Fee: No