



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-13326
Inspection Number: 03381086

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10036 COPENHAGEN ST PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/20/2017
Inspection Time: 12:00 AM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Approved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No