



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-10279

Inspection Number: 03383477

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8620 HUNTERS HILL LN LITTLETON

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 01/08/2018

Inspection Time: 12:00 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Rich Edgett

Charge Reinspection Fee: No

Comments

- 1) Loose recept at right of taps
- 2) Loose recept inbdrm under wall mirror
- 3) Remove dust cover from bdrm smoke det
- 4) CO / smoke det required outside of bdrms
- 5) Complete guard strips
- 6) re-label crkt #5 in subpanel "Card Table" not permitted