



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-10279

Inspection Number: 03383478

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 8620 HUNTERS HILL LN LITTLETON

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

### Inspection Details

Inspection Date: 01/08/2018

Inspection Time: 12:00 AM

Inspection Type: Final Building

Inspection Code: 108

Outcome: Disapproved

Inspected By: Brian Brown

Charge Reinspection Fee: No

### Comments

egress ladder bdrm 2

inlet strained at floor sink

AAV for Floor sink